

N61165.AR.005227
CNC CHARLESTON
5090.3a

LETTER REGARDING SOUTH CAROLINA DEPARTMENT OF HEALTH AND
ENVIRONMENTAL CONTROL APPROVAL OF MONITORING WELL INSTALLATION ZONE H
ABOVE GROUND STORAGE TANK 601 (AST 601) CNC CHARLESTON SC
07/11/2000
SOUTH CAROLINA DEPARTMENT OF HEALTH AND ENVIRONMENTAL CONTROL



11 July 2000

2600 Bull Street
Columbia, SC 29201-1708

COMMISSIONER:
Douglas E. Bryant

BOARD:
Bradford W. Wyche
Chairman

William M. Hull, Jr., MD
Vice Chairman

Mark B. Kent
Secretary

Howard L. Brilliant, MD

Brian K. Smith

Rodney L. Grandy

Larry R. Chewning, Jr., DMD

Department of the Navy
Southern Division NFEC
P.O. Box 190010
North Charleston, SC 29419-9010
Attention: Mr. Gabriel Magwood

Re: Assessment Plan dated 19 June 2000
Zone H/AST 601 (Site Identification # 01537)
Charleston Naval Complex/Charleston Naval Base
Charleston, SC
Charleston County

Dear Mr. Magwood:

The author has completed technical review of the referenced document. As submitted, the plan provides activities for additional environmental sampling to establish the extent and severity of soil and groundwater contamination at the subject site. Based on the information provided, the author concurs with the proposed assessments and the facility may implement activities at their discretion, as appropriate. Please find enclosed monitor well approval # 0847 for seven (7) DPT (direct push technology) sampling points. Should you have any questions please contact me at 803-898-3559 (land line), 803-898-3795 (fax) or bristolpl@gw.state.sc.us (e-mail).

Sincerely,

Paul L. Bristol, Hydrogeologist
Groundwater Quality Section
Bureau of Water

enc.: monitor well approval # 0847
cc: Trident District EQC



Date of Issue: 11 July 2000

Approval No: 0847

2600 Bull Street
Columbia, SC 29201-1708

Monitoring Well Installation Approval

COMMISSIONER:
Douglas E. Bryant

BOARD:
Bradford W. Wyche
Chairman

William M. Hull, Jr., MD
Vice Chairman

Mark B. Kent
Secretary

Howard L. Brilliant, MD

Brian K. Smith

Rodney L. Grandy

Larry R. Chewning, Jr., DMD

Approval is hereby granted to: Charleston Naval Complex/Charleston Naval Base
(on behalf of): Zone H/AST 601
Site ID#: 01537
County: Charleston

This approval is for the construction of seven (7) DPT (direct push technology) monitoring points designated (no designation) in accordance with the referenced construction plans and technical specifications submitted to the Department on 22 June 2000. The monitoring points are to be constructed within the surficial aquifer for the intended purpose of monitoring groundwater quality and/or water level(s) at the referenced facility. Approval is provided with the following conditions:

1. The surveyed elevations, boring and/or geologist logs and actual (as built) construction details for each well be submitted to within thirty (30) days of completion (of last well(s) installed).
(to be submitted with Assessment Report)
2. Well construction and sampling derived waste including, but not necessarily limited to, drill cuttings, drilling fluids, development and purge water should be managed properly and in compliance with applicable requirements. If containerized, each vessel should be clearly labeled with regard to contents, source, and date of activity.
3. A minimum of forty-eight (48) hours prior to initiation of drilling activities, please provide notice to Trident District EQC Office (843-740-1590).
4. Please provide groundwater quality analytical data (chemical analyses and/or water level(s)) and associated measurements (i.e., field measurements) to Paul L. Bristol within thirty (30) days of receipt from laboratory. (to be submitted with Assessment Report)
5. Monitoring wells shall be installed by a well driller certified by the State of South Carolina.
6. Each well shall be labeled with an identification plate constructed of a durable material affixed to the casing or surface pad where it is readily visible. The plate shall provide monitoring well I.D.#, date of construction, static water level, and driller name and state certification number.
(for permanent wells, only)

This approval is pursuant to the provisions of Section 44-55-40 of the 1976 South Carolina Code of Laws and the Department of Health and Environmental Control Regulations R.61-71.

Approved by:

Paul L. Bristol, P.G.
Groundwater Quality Section
Bureau of Water

cc: Trident District EQC